Hausadresse
IMA Materialforschung und Anwendungstechnik GmbH
Wilhelmine-Reichard-Ring 4 | 01109 Dresden | Germany
Postanschrift PF 80 01 44 | 01101 Dresden | Germany
Telefon +49(0)351 8837-0
Telefax +49(0)351 8804313

E-Mail ima@ima-dresden.de Internet www.ima-dresden.de Geschäftsführer
Prof. Dr.-Ing. Wilhelm Hanel (Sprecher)
E-Mail wilhelm.hanel@ima-dresden.de
Prof. Dr.-Ing. Thomas Fleischer
E-Mail thomas.fleischer@ima-dresden.de
Sitz der Gesellschaft: Dresden
Registergericht: Amtsgericht Dresden | HRB 5995
USt.-IdNr.: DE 155293995



Test report - short version

District heating pipe system-test manufactured by Brugg Rohrsystem AG (Type CALPEX-pipe)

Summary



Test Report No.: B044/11.2

Order No.: 302131001

Issued by Department of Plastics

Laboratory for Plastics Testing

Test report

Bonded pipe testing, CALPEX-pipe Test Report No.: B044/11.2



0 1				and the
SIII	TOOK	Ot.	tha	test:
Our	JICUL	OI	uic	1631

Pre-insulated flexible bonded pipe,

type CALPEX pipe

Customer:

Brugg Rohrsystem AG Industriestraße 39 CH-5314 Kleindöttingen

Delivery of the test objects:

2011-01-24

Period of tests:

2011-02 to 2011-03

Person in charge:

Dipl.-Ing. Döring

Distribution:

1 x Brugg Rohrsystem AG

2 x IMA Dresden

Reviewed and authorized.

Dresden, 31.03.2011 IMA Materialforschung und Anwendungstechnik GmbH

Prof. Dr.-Ing. Jens Ridzewski Head of Department Plastics


This is a translation and short version of the German test report B044/11.1 by Klaus-Dieter Döring.

The test results refer exclusively to the specimen under test.

The publication of parts of this test report and any reference to tests for advertising purposes is subject to written permission by IMA Materialforschung und Anwendungstechnik GmbH in any case.

Opinions and interpretations are not part of the accreditation. The results contained in this report may only be published or passed on to third parties with reference to the IMA Materialforschung und Anwendungstechnik GmbH.

Test report



Test Report No.: B044/11.2



Content

1.	Task definition	4
	Test objects	
3.	Test results	1

Test report

Bonded pipe testing, CALPEX-pipe

Test Report No.: B044/11.2



1. Task definition

On pre-insulated bonded flexible pipes type CALPEX, manufactured by Brugg Rohrsystem AG, the following selected properties are to be tested. The tests are to be carried out in accordance with EN 15632.

- Compressive creep (1000 h / 78 °C and 300 h / 93 °C)
- Carbon black content
- Thermal stability (OIT)
- Stress crack resistance (EN 60811-4-1:2004)
- Resistance to external actions (4 J, -20 °C)
- Flexibility
- Ring stiffness
- Water absorption (100 °C)
- Axial shear stress (23 °C)
- Linear water tightness

2. Test objects

- Pre-insulated bonded flexible pipe, type CALPEX, manufactured by Brugg Rohrsystem AG
- PUR-rigid-foam system: Cyclopentan blown high pressure PUR-foam
- Service pipe: PEX-a with EVOH-barrier, 63x5,8, SDR 11
- Delivery of the sample material to IMA Dresden: 2011-01-24
- Storage of the sample material before the test: Room climate

3. Test results

Test parameter	Test values (Average value)	Requirement of EN 15632	
Compressive creep (1000 h, 78 °C,12 N)	1,37 %	≤ 10 %	
Compressive creep (300 h, 93 °C,12 N)	0,78 %	≤ 10 %	
Carbon black content	3,4 %	≥ 2 %	
Thermal stability (OIT)	30,5 min	≥ 20 min	
Stress crack resistance (50 °C, 1000 h)	10 specimen, without damages	10 specimen, without damages (EN 60811-4-1)	
Resistance to external actions (-20 °C, 4 J)	no damages after 6 impacts	no damages after 6 impacts (EN 744)	
Flexibility Bending radius 1000 mm	no breaks in service pipe no breaks in casing pipe Ovality 2,1 % Cracks 2 mm to 3 mm	no breaks in service pipe no breaks in casing pipe Ovality ≤ 30 % Cracks ≤ 5 mm	
Flexibility Bending radius 750 mm	no breaks in service pipe no breaks in casing pipe Ovality 2,3 % Cracks 3 mm to 4 mm	no breaks in service pipe no breaks in casing pipe Ovality ≤ 30 % Cracks ≤ 5 mm	
Ring stiffness	29,4 kN/m²	≥ 4k N/m²	
Water absorption (100 °C, 90 min)	8,9 %	≤ 10 %	
Axial shear stress (23 °C)	0,20 MPa	≥ 0,09 MPa	
Linear water tightness (0,05 bar,168 h)	0 g / 168 h	≤ 100 g / 168 h	

The flexible CALPEX-pre-insulated pipe fulfil the requirements of the EN 15632-1:2009 and EN 15632-2:2009.

Dipl.-Ing. Döring Person in charge