

AS Onninen
Betooni 6/2
11415 TALLIN - ESTONIA

DECLARATION

Settimo Milanese, 07.02.2019

With this letter we certificate that our CANALSPLIT product are manufactured with below material technical data :

<u>Characteristics</u>	<u>Method</u>	<u>UM</u>	<u>Tolerance</u>	<u>Value</u>
Specific Weight	ISO 1183/87	Kg/dm ²	[± 0,03]	1,55
Yielding strength	ISO R 527/66	Kg/cm ²	>	390
Tensile strength	ISOR 527/66	Kg/cm ²	>	380
Elongation to break	ISO R 527/66	%	>	130
VICAT	ISO 306/74-Met.B	°C	[± 2]	82
Resilience IZOD	ISO 180/82	J/m	>	100
Hardness Shore D	ISO 868/85	Sh.D	[± 3]	82
Classification self-extinguish	UL 94			V0
Stabilization	Ca - Zn			

We communicate that all our raw materials are **RoHS certified**; with this document we declare total lack (or presence in minimum quantity as scripted in RoHS normative) of hazardous substances in all the article of our production.

Working temperature of our ducts system is -20°C / +60°C.

We herewith declare that our PVC compounds used to produce Canalsplit duct system is properly added to resist to UV RAYS.

ARTIPLASTIC MACOS S.R.L.