



TKK OÜ Tehnokontrollikeskus

Notified body No. 1336

EC TYPE-EXAMINATION CERTIFICATE

Directive 97/23/EC

Manufacturer: ARCTEST OY
Name and Address: Mikkellänkallio 20, FI-02770 Espoo, Finland

Assessed acc. to the directive 97/23/EC: EC-type examination, Module B

Equipment: Pressure vessel

Design/drawing No.: AT40; AT30

Identification of approved type: Vessel no. 0652/41

Versions of pressure equipment covered by approved type:

Designation	Maximum allowable pressure PS (bar)	Allowable temperature min/max TS (°C)	Volume V (L)
Refrigerant Receiver ATH40; ATV40	34,0	-10...+60	38
Refrigerant Receiver ATH30; ATV30	34,0	-10...+60	29


A list of the technical documentation, in one page, is annexed to this certificate.

OÜ Tehnokontrollikeskus hereby attests that the example of pressure equipment mentioned above fulfils the requirements of Directive 97/23/EC.

The applicant must inform OÜ Tehnokontrollikeskus of all modifications to the approved pressure equipment.

Certificate No.: 10-02-004-07
Certificate is renewable and valid until: 2017

Tallinn, January 29, 2007


Hillar Seeberg
Head of Conformity
Assessment Department



MEMBER OF CONFEDERATION OF
ORGANISATIONS FOR TESTING, INSPECTION,
CERTIFICATION AND PREVENTION

OÜ Tehnokontrollikeskus
Mustamäe tee 5, EE-10616 Tallinn, ESTONIA
tel +372 659 9470, fax + 372 659 9479