

EC TYPE-EXAMINATION CERTIFICATE

Directive 97/23/EC

Manufacturer: **ARCTEST OY**
Name and Address: Mikkelänkallio 20, FI-02770 Espoo, Finland

Assessed acc. to the
directive 97/23/EC: **EC-type examination, Module B**

Equipment: **Pressure vessel**
Design/drawing No.: **AT90**
Identification of
approved type: **Vessel no. 0647/8**

Versions of pressure equipment covered by approved type:


Designation	Maximum allowable pressure PS (bar)	Allowable temperature min/max TS (°C)	Volume V (L)
Refrigerant Receiver ATH90; ATV90	34,0	-10...+60	88
Refrigerant Receiver ATH50; ATV50	34,0	-10...+60	52
Refrigerant Receiver ATH75; ATV75	34,0	-10...+60	75
Refrigerant Receiver ATH100; ATV100	30,0	-10...+60	96

A list of the technical documentation, in one page, is annexed to this certificate.

OÜ Tehnokontrollikeskus hereby attests that the example of pressure equipment mentioned above fulfils the requirements of Directive 97/23/EC.

The applicant must inform OÜ Tehnokontrollikeskus of all modifications to the approved pressure equipment.

Certificate No.: **10-02-153-06**
Certificate is renewable and valid until: **2016**


Hillar Seeberg
Head of Conformity
Assessment Department

Tallinn, December 01, 2006