

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240473

Product: Cables with PVC insulation and PVC sheath for nominal voltage to 450/750 V

Type: NKT instal CYKY

Rating: (2-5) x (1,5-16) mm², 7 x (1,5-2,5) mm², 450/750 V

Ordering firm: NKT S.A.
ul. Gajowa 3, 43-254 Warszawa, Poland

Manufacturer: NKT S.A.
ul. Gajowa 3, 43-254 Warszawa, Poland

Factories: NKT S.A.
ul. Gajowa 3, 43-254 Warszawa, Poland

Trade mark:

The test results are stated in the test-report No.: 242116-01/01 of: 27.09.2024

A sample of the product was found to be in conformity with:

ČSN EN 50395:06+A1:2012, ČSN EN 50396:2006+A1:2012, ČSN EN 50363-3:2006+A1:2012,
ČSN EN 50363-4-1:2006, ČSN EN 60811-100:2013, ČSN EN 60811-401:2013+A1:2018,
ČSN EN 60811-201:2013+A1:2018+A2:2024, ČSN EN 60811-202:2013+A1:2018+A2:2024, ČSN EN 60811-203:2013,
ČSN EN 60811-409:2013, ČSN EN 60811-501:2013+A1:2019+A2:2024, ČSN EN 60811-504:2013,
ČSN EN 60811-508:2013+A1:2018+A2:2024, ČSN EN 60811-509:2013+A1:2018,
ČSN EN 60332-1-1:2005+A1:2016, ČSN EN 60332-1-2:2005+A1:2016+A11:2017+A12:2021

Other data:

The validity of the certificate is limited to: 02.10.2027

03.10.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



242116-01