PREMIUM Certificate

no. c9711a-25

Customer:

Assmann Electronic GmbH
Auf dem Schüffel 3
58513 Lüdenscheid, Germany

VALID TO NOVEMBER 2025

Category 7A

Test sample(s):

Balanced cable:
DIGITUS® CAT 7A, Class FA, S/FTP Pimf AWG 22/1 Installation Cable
Part-no.: DK-1743-A-VH-5, DK-1743-A-VH-10, DK-1743-A-VH-D-5
DK-1744-A-VH-5, DK-1744-A-VH-10, DK-1744-A-VH-D-5
DK-1745-A-VH-5, DK-1745-A-VH-10, DK-1745-A-VH-D-5

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)
DIN EN 50173-1 (2018-10)
IEC 61156-5 Ed.3.0 (2020-04)

Result(s):

The sample meets the limits of the applied standards and regulations with respect to the parameters indicated above.

Balanced cable, copper, Category 7A

GHMT PREMIUM Verification Program, GHMT PVP

Ongoing compliance with the specifications is monitored within the framework of regular sampling, which cannot be influenced by the customer, thus defining high standards as regards continuous manufacturing quality.

This Certificate refers to the comprehensive test report **no. R9711a-25** and shall only be applicable in conjunction with the test report.

Bexbach, 16.09.2025

Dirk Wilhelm, engineer
(Chairman of the Managing Board)

Test laboratory accredited by DAkkS in accordance with DIN EN ISO/IEC 17025:2018.
*The accreditation is valid for the test methods listed in certificate **D-PL-17559-01-00**.*

GHMT AG
In der Kolling 320
66450 Bexbach / Germany

PO box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.