

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Certificate No.
2821-CPR-0256

Issue date
29-June-2023

Issue No.
3

Re-Issue date
30-04-2025

In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product and placed on the market under the name or trademark of

Manufacturer:

Mulcol International BV

Address:

Promenade 75, 5401GM Uden, The Netherlands

Product:

Mulcol® Multisealant GR

Places of production:

L/002


Harmonized requirements

EAD 350454-00-1104, September 2017

Scope of Certificate

ETA 23/0055, issued on 24/04/2025

Deputy Head of Notified Body:



Koen Schilleman

Issued by UL International (Netherlands) B.V., Notified Body 2821.



This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the ETA 23/0055 and EAD 350454-00-1104 under system 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 29-06-2023 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Economic Operators:

Manufacturer: Mulcol International BV
Manufacturers Address: Promenade 75, 5401GM Uden, The Netherlands

Detailed information sheet:

Product Reference: Mulcol® Multisealant GR
Type: Sealant
Description: Mulcol® Multisealant GR is a sealant and pipe closure device used to form penetration seals where insulated and uninsulated metal pipes, combustible pipes, combustible cable conduits and cables penetrate walls and floors.
Key Performance parameters: See ETA 23/0055
Identification and intended use: Penetration Sealing System
CE marking method: Label

Limitations on the acceptance or use of the product(s):

Installation instructions: To be used in accordance with the supplier's installation instructions, and technical datasheet and the ETA
Limitations: See Technical Data Sheet and the ETA

Revision Table:

Version	Project Number	Date	Description
1.0	4790841432	2023-06-29	Initial
2.0	4791205742	2024-04-30	New ETA basis
3.0	SR 6025642.1498306	2025-04-30	Amendment to Manufacturer Address

Terms and Conditions:

1. This certificate remains the property of UL International (NL) B.V, herein "UL NL", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL NL.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL NL.
5. This certificate is only valid for placing goods on the EU market.
6. The requirements for the economic operators stipulated in CHAPTER II, Article 4 of the Regulation (EU) 2019/1020 of the European Parliament and of the Council of 20 June 2019

END OF CERTIFICATE