

Certificate of compliance

Applicant: Ginlong Technologies Co., Ltd.
No.57 Jintong Road Binhai Industrial Park Xiangshan 315712 Ningbo Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: Hybrid Inverter

Model: S6-EH3P5K2-H(21A), S6-EH3P6K2-H(21A), S6-EH3P8K2-H(21A),
S6-EH3P10K2-H(21A), S6-EH3P5K-H-EU(21A), S6-EH3P6K-H-EU(21A),
S6-EH3P8K-H-EU(21A), S6-EH3P10K-H-EU(21A), S6-EH3P12K-H-EU(21A)

The device is designed to work as a generation unit of the type: A

Inverter for three-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019/A1:2023

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.12 Remote information exchange
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

EN 50549-10:2022

Requirements for generating plants to be connected in parallel with distribution networks - Part 10: Tests for conformity assessment of generating units

Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG).
Type approval for generation units to use in Type A plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: CCCV-ESH-P23110058-R1-A1

Certificate number: U25-0756

Certification Program: NSOP-0032-DEU-ZE-V10

Date of issue: 2025-08-21

Certification body

Accreditation



Domenik Koll
Head of Energy Systems Germany



Accredited certification body by Deutsche Akkreditierungsstelle GmbH (DAkkS) according to ISO/IEC 17065. The accreditation is valid only for the scope listed in the annex of the accreditation certificate D-ZE-12024-01-00. The Deutsche Akkreditierungsstelle GmbH (DAkkS) is signatory of the multilateral arrangements of EA, ILAC and IAF for mutual recognition.

Without the written consent of Bureau Veritas Consumer Products Services Germany GmbH excerpts of this certificate of conformity shall not be reproduced.

Type Approval and declaration of compliance with the requirements of EN 50549-1 and Commission Regulation (EU) 2016/631 of 14 April 2016				
Manufacturer	Ginlong Technologies Co., Ltd. No.57 Jintong Road Binhai Industrial Park Xiangshan 315712 Ningbo Zhejiang PEOPLE'S REPUBLIC OF CHINA			
Product type	Hybrid Inverter			
Static converter model	S6-EH3P5K2-H(21A)	S6-EH3P6K2-H(21A)	S6-EH3P8K2-H(21A)	S6-EH3P10K2-H(21A)
Input DC (photovoltaic)				
MPP voltage range [V]	200-850	200-850	200-850	200-850
Max. input voltage [V]	1000	1000	1000	1000
Max. input current per MPPT [A]	21/21	21/21	21/21	21/21
Input DC (battery)				
DC voltage range [V]	120-700	120-700	120-700	120-700
Max. DC voltage [V]	700	700	700	700
Max. DC current per DC input [A]	25	25	50	50
Output AC				
Rated AC voltage [V]	3L/N/PE, 230/400V, 50Hz	3L/N/PE, 230/400V, 50Hz	3L/N/PE, 230/400V, 50Hz	3L/N/PE, 230/400V, 50Hz
Rated output current [A]	7,2	8,7	11,5	14,4
Max. output current [A]	7,2	8,7	11,5	14,4
Nom. converter output (P _{NINV}) [kW]	5,0	6,0	8,0	10,0
Max. apparent power [kVA]	5,0	6,0	8,0	10,0
Static converter model	S6-EH3P5K-H-EU(21A)	S6-EH3P6K-H-EU(21A)	S6-EH3P8K-H-EU(21A)	S6-EH3P10K-H-EU(21A)
Input DC (photovoltaic)				
MPP voltage range [V]	200-850	200-850	200-850	200-850
Max. input voltage [V]	1000	1000	1000	1000
Max. input current per MPPT [A]	21/21/21	21/21/21	21/21/21/21	21/21/21/21
Input DC (battery)				
DC voltage range [V]	120-700	120-700	120-700	120-700
Max. DC voltage [V]	700	700	700	700
Max. DC current per DC input [A]	25	25	50	50
Output AC				
Rated AC voltage [V]	3L/N/PE, 230/400V, 50Hz	3L/N/PE, 230/400V, 50Hz	3L/N/PE, 230/400V, 50Hz	3L/N/PE, 230/400V, 50Hz
Rated output current [A]	7,2	8,7	11,5	14,4
Max. output current [A]	7,2	8,7	11,5	14,4
Nom. converter output (P _{NINV}) [kW]	5,0	6,0	8,0	10,0
Max. apparent power [kVA]	5,0	6,0	8,0	10,0

Static converter model	S6-EH3P12K-H-EU(21A)	--	--	--
Input DC (photovoltaic)				
MPP voltage range [V]	200-850	--	--	--
Max. input voltage [V]	1000	--	--	--
Max. input current per MPPT [A]	21/21/21/21	--	--	--
Input DC (battery)				
DC voltage range [V]	120-700	--	--	--
Max. DC voltage [V]	700	--	--	--
Max. DC current per DC input [A]	50	--	--	--
Output AC				
Rated AC voltage [V]	3L/N/PE, 230/400V, 50Hz	--	--	--
Rated output current [A]	17,3	--	--	--
Max. output current [A]	17,3	--	--	--
Nom. converter output (P _{NINV}) [kW]	12,0	--	--	--
Max. apparent power [kVA]	12,0	--	--	--

Interface protection system and interface switch (Network and system protection "NS-protection")	
Type of protection	Integrated NS-protection
Assigned to generation unit type	S6-EH3P5K2-H(21A), S6-EH3P6K2-H(21A), S6-EH3P8K2-H(21A), S6-EH3P10K2-H(21A), S6-EH3P5K-H-EU(21A), S6-EH3P6K-H-EU(21A), S6-EH3P8K-H-EU(21A), S6-EH3P10K-H-EU(21A), S6-EH3P12K-H-EU(21A)
Integrated interface switch	For models: S6-EH3P5K2-H(21A), S6-EH3P6K2-H(21A), S6-EH3P8K2-H(21A), S6-EH3P10K2-H(21A), S6-EH3P5K-H-EU(21A), S6-EH3P6K-H-EU(21A), S6-EH3P8K-H-EU(21A), S6-EH3P10K-H-EU(21A)
	Type of switching equipment 1: Relay (Model ALFG-PF) Type of switching equipment 2: Relay (Model ALFG-PF)
	For models: S6-EH3P12K-H-EU(21A)
	Type of switching equipment 1: Relay (Model HF161F-40W/12-HTF(967)) Type of switching equipment 2: Relay (Model HF161F-40W/12-HTF(967))
	Note: The output is switched off by the inverter bridge and two relays in series in each line and neutral.
Firmware version	A2
Note The settings of the interface protection are password protected adjustable. In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration. The above stated generators are tested according to the requirements in the EN 50549-1:2019 Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.	

Parameter Table				
Name of parameter set		EN50549-1		
specific technical requirement (e.g. grid codes)		EN50549-1		
Clause(s) / subclause(s) of EN 50549-1:2019 or EN 50549-2:2019	Parameter ^a	Remarks/ additional information ^b	configurable value range	default value
4.3.2 Interface switch	Single fault tolerance for interface switch		yes no	yes
4.4.2 Operating frequency range	47,0 – 47,5 Hz Duration		0 s – 20 s	0s
	47,5 – 48,5 Hz Duration		30 – 90 min	30 min
	48,5 – 49,0 Hz Duration		30 – 90 min	30 min
	49,0 – 51,0 Hz Duration		not configurable	unlimited
	51,0 – 51,5 Hz Duration		30 – 90 min	30 min
	51,5 – 52,0 Hz Duration		0 – 15 min	0 s
4.4.3 Minimal requirement for active power delivery at underfrequency	Reduction threshold		not configurable 49,0 Hz – 49,5 Hz	Electronic inverter, no power reduction take place 49,5 Hz
	Maximum reduction rate		not configurable 2 – 10% P _M /Hz	≤ 2 % 10% P _M /Hz
4.4.4 Continuous operating voltage range	Upper limit		not configurable 1,0 U _n – 2,0 U _n	1,15 U _n 1,10 U _n
	Lower limit		not configurable 0,9 U _n – 1,0 U _n	0,85 U _n , 0,90 U _c
4.5.2 Rate of change of frequency (ROCOF) immunity	ROCOF withstand capability (defined with a sliding measurement window of 500 ms) non-synchronous generating technology (inverter): synchronous generating technology:		not configurable 0 – 10 Hz/s	
		yes		2 Hz/s
		no		1 Hz/s

4.5.3.2 Under-voltage ride through (UVRT) Generating plant with non-synchronous generating technology (inverter)	Voltage-Time- Diagram		see Figure 6 of EN 50549-1:2019 and EN 50549-2:2019	Time [s]	U [p.u.]
				0,00	0,20
				0,15	0,20
				1,50	0,85
				180	0,85
				180	0,90
	Fast fault current		Rated value	S6-EH3P5K2-H(21A): 7,2A S6-EH3P6K2-H(21A): 8,7A S6-EH3P8K2-H(21A): 11,5A S6-EH3P10K2-H(21A): 14,4A S6-EH3P5K-H-EU(21A): 7,2A S6-EH3P6K-H-EU(21A): 8,7A S6-EH3P8K-H-EU(21A): 11,5A S6-EH3P10K-H-EU(21A): 14,4A S6-EH3P12K-H-EU(21A): 17,3A Note: Rated current of internal safety device!	
	Active power recovery after a short circuit		configurable	Start at 90% U_n	
	Fault recovery of active power (times calculated from the removal of the short circuit)		configurable	≤ 5 s	
	Value for recovered active power		configurable	≥ 90 %	
	Accuracy for recovery of active power		not configurable	≤ 10 %	
	Reactive power contribution has priority		yes no	Yes	
4.5.4 Over-voltage ride through (OVRT)	Voltage-Time- Diagram		not configurable see Figure 8 of EN 50549-1:2019 and EN 50549-2:2019	Time [s]	U [p.u.]
				0,0	1,25
				0,1	1,25
				0,1	1,20
				5,0	1,20
				5,0	1,15
				60,0	1,15
				60,0	1,10
	Active power recovery after a short circuit		configurable	Start at 90% U_n	
	Fault recovery of active power (times calculated		configurable	≤ 5 s	

	from the removal of the short circuit)			
	Value for recovered active power		configurable	$\geq 90\%$
	Accuracy for recovery of active power		not configurable	$\leq 10\%$

4.6.1 Power response to overfrequency	Threshold frequency f_1		50,2 Hz – 52,0 Hz	50,2 Hz
	Droop		2% – 12%	5%
	Power reference		$P_M P_{max}$	P_{max} , for synchronous generating technology and EESS P_M for other non-synchronous generating technology (inverter)
	Intentional delay		0 s – 2 s	0 s
	Deactivation threshold f_{stop}		50,0 Hz – f_1	deactivated
	Deactivation time t_{stop}		0 s – 600 s	-
	Acceptance of staged disconnection		yes no	yes
4.6.2 Power response to underfrequency	Threshold frequency f_1		49,8 Hz – 46,0 Hz	49,8 Hz
	Droop		2 % – 12%	5%
	Power reference		$P_M P_{max}$	P_{max}
	Intentional delay		0 s – 2 s	0 s
4.7.2.2 voltage support by reactive power - Capabilities	Active factor / Reactive power (% P_d) range overexcited		0,90 – 1 / 48% P_d - 0 0,95 – 1 / 33% P_d - 0	0,95 – 1 / 33% P_d - 0
	Active factor / Reactive power (% P_d) range underexcited		0,90 – 1 / 48% P_d - 0 0,95 – 1 / 33% P_d - 0	0,95 – 1 / 33% P_d - 0
4.7.2.3 voltage support by reactive power - Control modes	Enabled control mode		Q setp. Q(U) Q(P) cos φ setp. cos φ (P)	activated deactivated deactivated deactivated deactivated
4.7.2.3.2 voltage support by reactive power - Set point control modes	Q set point and excitation		0% – 48% P_D , 0% – 33% P_D	0
	cos φ set point and excitation		1,0 – 0,9	1
4.7.2.3.3 voltage support by reactive power - Voltage related control modes	Characteristic curve		cos φ (P) Q(P)	indicate default characteristic
	Time constant		3 s – 60 s	10 s
	Min cos φ		0,0 – 1	0,9
	Lock-in power		0% – 20%	deactivated
	Lock-out power		0% – 20%	deactivated
4.7.2.3.4 voltage support by reactive power - Power related control mode	Characteristic curve		Q(U) P(U)	Q(U) (three-phase inverter) 0,00...-0,436 0,92...-0,436 0,94...0,0 1,06...0,0 1,08...0,436 1,20...0,436 P(U) deactivated
	Enabling		enable disable	disable

4.7.4.2.2 Zero current mode for converter connected generating technology / Generating Plant with non- synchronous generator	Static voltage range overvoltage		100% U_n – 120% U_n	120% U_n
	Static voltage range undervoltage		20% U_n – 100% U_n	50% U_n

4.9.3 Requirements on voltage and frequency protection	Threshold for protection as dedicated device [in A or kW, kVA]		HF161F-40W/12-HTF(967): 40A; ALFG-PF: 33A Note: Rated current of internal safety device!	Internal safety device
	Undervoltage threshold stage 1		$0,2 U_n - 1 U_n$	$0,85 U_n$
	Undervoltage operate time stage 1		$0,1 s - 100 s$	$1,2 - 1,5 s$
	Undervoltage threshold stage 2		$0,2 U_n - 1 U_n$	N/A
	Undervoltage operate time stage 2		$0,1 s - 5 s$	N/A
	Overvoltage threshold stage 1		$1,0 U_n - 1,2 U_n$	$1,15 U_n$
	Overvoltage operate time stage 1		$0,1 s - 100 s$	$0,1 - 0,2 s$
	Overvoltage threshold stage 2		$1,0 U_n - 1,3 U_n$	$1,25 U_n$ (N/A)
	Overvoltage operate time stage 2		$0,1 s - 5 s$	$0,1 s$ (N/A)
	Overvoltage threshold 10 min mean protection		$1,0 U_n - 1,15 U_n$	$1,10 U_n$
	Overvoltage operate time 10 min mean protection		$0,04 s - 10,00 s$	10 min (update every 3s)
	Underfrequency threshold stage 1		$47,0 Hz - 50,0 Hz$	$47,5 Hz$
	Underfrequency operate time stage 1		$0,1 s - 100 s$	$0,3 s - 0,5 s$
	Underfrequency threshold stage 2		$47,0 Hz - 50,0 Hz$	N/A
	Underfrequency operate time stage 2		$0,1 s - 5 s$	N/A
	Overfrequency threshold stage 1		$50,0 Hz - 52,0 Hz$	$52,0 Hz$
	Overfrequency operate time stage 1		$0,1 s - 100 s$	$0,3 s - 0,5 s$
	Overfrequency threshold stage 2		$50,0 Hz - 52,0 Hz$	N/A
	Overfrequency operate time stage 2		$0,1 s - 5,0 s$	N/A
	Loss of mains according EN 62116 (LoM)		$0 s - 6000 s$	ROCOF $2,5 Hz/s$ ($0,5 s$) active $2 s$ ($5 s$)

only EN 50549-2:2019, 4.9.3 Requirements on voltage and frequency protection	Positive sequence under- voltage protection threshold		20% – 100%	
	Positive sequence under- voltage protection operate time		0,2 s – 100 s	
	Negative sequence over- voltage protection threshold		1% – 100%	
	Negative sequence over- voltage protection operate time		0,2 s – 100 s	
	Zero sequence over- voltage protection threshold		1% – 100%	
	Zero sequence over- voltage protection operate time		0,2 s – 100 s	
4.10.2 Automatic reconnection after tripping	Lower frequency		47,0 Hz – 50,0 Hz	49,5 Hz
	Upper frequency		50,0 Hz – 52,0 Hz	50,2 Hz
	Lower voltage		50% U _n – 100 % U _n	85% U _n , 90% U _c
	Upper voltage		100% U _n – 120% U _n	110% U _n
	Observation time		10 s – 600 s	60 s
	Active power increase gradient		6% – 3000% / min	10% / min
4.10.3 Starting to generate electrical power	Lower frequency		47,0 Hz – 50,0 Hz	49,5 Hz
	Upper frequency		50,0 Hz – 52,0 Hz	50,1 Hz
	Lower voltage		50% – 100% U _n	85% U _n , 90% U _c
	Upper voltage		100% – 120% U _n	11% U _n
	Observation time		10 s – 600 s	60 s
	Active power increase gradient		6% – 3000% / min	disabled
4.11.1 Ceasing active power	activation option		RJ45, WILAN	
4.11.2 Reduction of active power on set point	activation option		RJ45, WILAN	
4.12 Remote information exchange	available communication standards		N/A	
^a If additional parameters have been evaluated during the test, these shall be added as additional lines in the table.				
^b This column should be used for manufacturer specific parameter descriptions.				