

DECLARATION OF PERFORMANCE No. 1/AI/2026

1. Name and trade name of the construction product:

Ball valves, brand: TiA

2. Construction product type designation

Index: F-2065066, F-2065059, F-2065077, F-2065080,

Index: F-2065186, F-2065186-V2, F-2065132, F-2065132-V2, F-2065076, F-2065079

Index: F-2065100, F-2065101

3. Intended use(s):

Installation components intended for use as shut-off valves in heating systems, where the working medium is water.

4. Name and address of the manufacturer's registered office:

TiA sp. z o.o., ul. Głęboka 34, 37-200 Przeworsk

Place of production: PRC

5. Name and registered address of the authorized representative, if any:

Not applicable

6. National system of assessment and verification of constancy of performance of the construction product: System 4

7. National technical specification:

7a. Polish Product Standard:

PN-EN 13828-2005

Name of the accredited certification body, accreditation number and national certificate number, or name of the accredited laboratory/laboratories and accreditation number: Not applicable

7b. National Technical Assessment: Not applicable

Technical Assessment Body/National Technical Assessment Body: Not applicable

Name of the accredited certification body, accreditation number and certificate number: Not applicable

8. Declared performance:


Essential characteristics of the construction product for the intended use(s)	Declared performance	Remarks
Maximum working pressure	1,6 MPa	
Maximum operating temperature	100°C	

9. The performance of the product identified above is in conformity with all the declared performances listed in point 8. This national declaration of performance is issued in accordance with the Act of 16 April 2004 on construction products, under the sole responsibility of the manufacturer.

Signed for and on behalf of the manufacturer:

Adam Ślonda, Vice President
of the Management Board

Przeworsk, 15.01.2026r.

TiA Sp. z o.o.
Wiceprezes Zarządu

.....
(name, surname and position)

.....
(place and date of issue)