



CERTIFICATE FI 29266

Our Ref. 280811-1

Product

Cables for fixed wiring

Type

AHXAMK-W

Trade mark

ENERGOCOMPLEKT

Certificate Holder/ Manufacturer

Energocomplekt Co., Ltd. Moskovsky av., 94B

210035 VITEBSK **BELARUS**

Technical information

Number and nominal cross-sectional area of conductors:

3x16-300 Al/16-35 Cu

Other information

Nominal voltages:

6/10 kV (Um=12 kV)

12/20 kV (Um=24 kV) 18/30 kV (Um=36 kV)

Sheath PE, laid up around bare earth conductor

See the Appendix to this Certificate

The product is certified according to the following standard(s)

HD 620 S2:2010 Part 10 Section F

Validity

This certificate is valid until 14 September 2020 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Directive information

The product(s) fulfils the essential safety requirements for CE conformity marking according to the

Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.

Date of issue

14 September 2015

SGS Fimko Ltd

Signature

Sixten Lökfors Project Manager



This certificate has 1 appendix

This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.filen/Terms-and-Conditions.aspx. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



Appendix to Certificate: 29266

Manufacturing site

Energocomplekt Co., Ltd. Moskovsky av., 94B 210035 VITEBSK BELARUS

Additional information



This certificate is based on partial testing by SGS Fimko in own premises with Test Report 280811-1 and on IPH Berlin Test Report NO. 00724-15-0189 dated 12 June 2015 and EZU/ETI Test Report 502337-01/01 issued 10.07.2015.