

# CERTIFICATE FI 29266 M1



Our Ref. 280811-1, 289323-1

**Product** Cables for fixed wiring

**Type** AHXAMK-W  
AHXAMK-WP

**Trade mark** ENERGOCOMPLEKT

**Certificate Holder/  
Manufacturer** Energocomplekt Co., Ltd.  
Moskovsky av., 94B  
210035 VITEBSK  
BELARUS

**Technical information** Number and nominal cross-sectional area of conductors:  
3x16-300 Al/16-35 Cu

**Other information** Nominal voltages: 6/10 kV (Um=12 kV)  
12/20 kV (Um=24 kV)  
18/30 kV (Um=36 kV)  
Sheath PE  
See the Appendix to this Certificate

**The product is certified  
according to the  
following standard(s)** HD 620 S2:2010 Part 10 Section F

**Validity** This certificate is valid until 14 September 2020 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.

**Directive information** The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

**Date of issue** 13 June 2017

**SGS Fimko Ltd**

**Signature**

  
Sixten Lökfors  
Project Manager


This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Ltd.

Särkiniementie 3 P.O.Box 30 FI-00211 Helsinki, Finland  
t. +358 9 696 361 f. +358 9 692 5474 [www.sgs.fi](http://www.sgs.fi)

Business ID 0978538-5

Member of the SGS Group (SGS SA)

Appendix to Certificate: 29266 M1

**Manufacturing site**

Energocomplekt Co., Ltd.  
Moskovsky av., 94B  
210035 VITEBSK  
BELARUS

**Additional information**



This certificate is based on partial testing by SGS Fimko in own premises with Test Report 280811-1 and on IPH Berlin Test Report NO. 00724-15-0189 dated 12 June 2015 and EZU/ETI Test Report 502337-01/01 issued 10.07.2015.

**AHXAMK types:**

- W: watertight with a plain copper earthing wire in the middle
- WP: watertight without copper earthing wire

This certificate replaces Certificate FI 29266 dated 14 September 2015, due to added type.