

# Declaration of Conformity

**Danfoss A/S**  
**District Energy Division**  
**DK-6430 Nordborg, Denmark**

Declares under our sole responsibility that

**Pressure Independent Balancing & Control valves with accessories**

<u>Valve Type</u>	<u>Year of affixed CE Mark</u>
AB-QM DN10-32	2004
AB-QM DN40	2009
AB-QM DN50	2008
AB-QM DN65-100	2008

to which this declaration relates, are in conformity with the following directives, provided that they are used according to our instructions.

**PED-directive 97/23/EEC**

PN (PS)	DN<=32	DN 40	DN 50	DN 65	DN 80	DN 100	DN 125	DN 150	DN 200	DN 250
6	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Cat. I module A	Cat. I module A
10	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A
16	Art. 3§3	Art. 3§3	Art. 3§3	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. II module H


Conformity assessment procedures according to PED – Annex III.

**Bureau Veritas** (0041) will currently conduct inspection.

Products according to PED – Article 3§3 are not CE-marked.

*Ljubljana 5<sup>th</sup> February, 2011*

*Place and date of issue*



*Aleksander Zalaznik, Vice president, DEN Controls*



**Danfoss Trata d.o.o.**