

CERTIFICATE FI/40509/A1

Our Ref. HEL-CERT191200797-02



Product Switchgear and controlgear assembly system

Type AHMA

Certificate Holder Utu Oy
Ahjontie 1
FI-28400, Ulvila, Finland

Technical information I_{nA} 800 A (max), U_n 690 V (max), 3/N/PE, IP34...IP54

Other information See page 2 of this Certificate

The product is certified according to the following standard(s) EN 61439-1:2011
EN 61439-2:2011
EN 61439-3:2012

Validity This certificate is valid until 2026-06-30 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 2024-06-13

SGS Fimko Ltd

Signature


Jonas Leinonen
Certification Manager



Manufacturer	Utu Oy Ahjontie 1 FI-28400, Ulvila, Finland	
Manufacturing site	Same as manufacturer	
Directive information	The certified product(s) fulfils requirements of mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.	
Additional information	Short-circuit strength (max) EMC Environment Functional units Enclosure - Degree of protection (EN 60529) - Mechanical strength (EN 62262) - Protection class against electric shock - Material Installation method floor	Icw 25 kA, Ipk 52,5 kA A and/or B Fixed parts EN 62208 IP34...IP54 IK08 I Metallic For surface mounting / standing

A degree of protection provided by enclosure (IP34...IP54) of a switchgear and controlgear assembled from the switchgear and controlgear assembly system is determined taking into account the IP code of the enclosure to be used, and the tightness (IP code) of the components installed through the enclosure.

It shall be verified that the components to be used in the switchgear and controlgear assembly comply with the relevant standards.

The EMC requirements for the switchgear and controlgear assembly are given in Annex J of standard EN 61439-1.

The items to be agreed upon by the manufacturer and the user/orderer of the switchgear and controlgear assembly are given in Annex C of standard EN 61439-1.

The conformity of switchgear and controlgear assembled from the switchgear and controlgear assembly system with the design of the tested assembly and fulfilment of the requirements given in the standards for which the certification of the system is based on shall be verified by routine tests (EN 61439-1 clause 11).

This certificate replaces Certificate FI/40509 dated 2019-12-12, due to validity extension.

Based on: 277855-1, 257446-1, 298353-1