


DSCC-S6R
Signalkontakt
Signal Contact
2CDS200933R0013

ABB AG – STOTZ-KONTAKT
Eppelheimer Str. 82
DE-69123 Heidelberg
go.abb/contact

ABB

ABB Limited
Tower Court
Coventry
CV6 5NX, UK




EN: Warning! Installation by person with electrotechnical expertise only.
DE: Warnung! Installation nur durch elektrotechnische Fachkraft.
IT: Avvertenza! Fare installare solo da un elettricista qualificato.
FR: Avertissement! Installation uniquement par des personnes qualifiées en électro technique.
ES: ¡Advertencia! La instalación deberá ser realizada únicamente por electricistas especializados.



2CDS200928P0014 Rev. B

UK
CA

Compatibility with main devices	C		
DSE201 NS			
DSN201E	✓	✓	
GS201C			
S201NC			
DS202CR	✓		✓





SIGNALING FUNCTIONALITY

Function	Main Device	Signaling
Signaling	Tripped	
Reset	Tripped	
Test	Toggle OFF	



EN: Only switch operating handle when assembled to protection device.
DE: Schaltgriff nur in montiertem Zustand am Schutzgerät betätigen.
IT: Azionare la leva di comando solo quando assemblata al dispositivo di protezione.
FR: Actionner la manette de commande uniquement lorsqu'elle est assemblée sur le dispositif de protection.
ES: Solo accionar la maneta una vez acoplado al dispositivo de protección.

Connection with DS202CR



Connection with DSE201 NS, DSN201E, GS201C, S201NC

