



DECLARATION OF PERFORMANCE NO: 1000174-SEGR

Date: 30/01/2017

Product Family Name

MCMK-HF/EXQJ 1 KV (CPR)

(see list of corresponding products and unique identification codes hereafter)

Intended use of the product

Cable for general applications in construction works subject to reaction to fire requirements

AVCP (Assessment and Verification of Constancy of Performance): System 3

Notified body: 0366

Declared performance and Harmonized Standard

ESSENTIAL CHARACTERISTIC	PERFORMANCE	HARMONIZED STANDARD
Reaction to fire Dca -s2,d2,a2		according to EN50575:2014+A1:2016
Release of dangerous substances	NPD	NA

The performance of the product mentioned above is in conformity with the declared performance.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer.

Manufacturer Nexans Sweden AB

SE-514 81 GRIMSÅS Sweden

Signed for the manufacturer by Inge Adolfsson inge.adolfsson@nexans.com Nexans Sweden AB 30/01/2017

Luye Selem





You will find hereafter the list of CPR certified products for the selected family

Nexans ref.	Country ref.	Product Name
15121698	0622841	EXQJ 1 kV 3X2,5/2,5
15121898	0622843	EXQJ 1 kV 3X6/6
15121998	0622845	EXQJ 1 kV 3X10/10
15123198	0622842	EXQJ 1 kV 4X2,5/2,5
15123398	0622844	EXQJ 1 kV 4X6/6
15123498	0622846	EXQJ 1 kV 4X10/10