Ref. Certif. No.

SE-91506

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch-disconnectors
Name and address of the applicant	Schneider Electric Industries SAS Electropole 31 rue Pierre Mendes France-38050 GRENOBLE Cedex 9-France
Name and address of the manufacturer	Same as applicant
Name and address of the factory Note: *When more than one factory, please report on page 2*	WuHu Schneider Power Distribution Apparatus Manufacturing Co., Ltd., No. 2378, Yangguang Avenue, Xinwu Economic Development Zone, Wuhu County, Wuhu City, Anhui province China
Ratings and principal characteristics	Ue= 230V~(1P), 400V~(2P, 3P, 4P) Ie= 40, 63, 80, 100,125A I_{cw}= 12I_e / 1s, I_{cm}= 15I_e, I_{cc}= 5kA, U_i= 500V, U_{imp}= 4kV, Cat. AC-22A
Trademark (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	Easy9
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2007+A1+A2 IEC 60947-3:2008+A1+A2
As shown in the Test Report Ref. No. which forms part of this Certificate	180601522SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 31 July 2018

intertek

Signature:

Helen Gustafsson