

CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



STATEMENT OF TEST RESULTS

STR/2616/IMQ

Product	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)
Tested by request of	SCHNEIDER ELECTRIC INDUSTRIES SAS 31 rue Pierre Mendès France, Eybens F-38050 Grenoble Cedex 9 – France
Manufactured at (name and place)	SCHNEIDER ELECTRIC ESPAÑA, S.A. Camino Barranquet, 57 46133 Meliana (Valencia) – Spain
Preliminary visit carried out by	—
Rating and principal characteristics	1P+N – Un = 230 V – Curve B or C In = 4, 6, 10, 13, 16, 20, 25, 32 or 40 A type A, Asi or AC – IΔn = 10, 30 or 300 mA Icn = 6000 A – IΔm = 3000 or 4500 A (see also Additional Sheet and pages 6, 8 and 9 of Test Report PB20-0052000-01-00)
Trade mark (if any)	
Model/Type Ref.	Series DPN Vigi (see also Additional Sheet and pages 8 and 9 of Test Report PB20-0052000-01-00)
Additional information (if necessary)	—
<i>A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)</i>	
• EN 61009-1:2012 + A1:2014 + A2:2014 + A11:2015 + A12:2016 • EN 61009-2-1:1994 + A11:1998	
as shown in the test reports (reference No.)	PB20-0052000-01-00 and from PB20-0052000-01-01 to PB20-0052000-01-31

This Statement of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the above mentioned standard.

This Statement of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA may recognize this Statement as a basis for granting a national mark of conformity or a national approval, as specified in OD 6, List of current decisions of CCA Group, point 2.11.

IMQ S.p.A.

Milano, 2020-09-01

Signature of the authorized person

Name and function of the authorized person

Mauro Casari

**B.U. "Product Conformity Assessment"
"Project Management & Certification" Area
"Certification" Sector (voluntary field) - Manager**

Tel.: (+39) 02-50731
Fax.: (+39) 02-50991500
e-mail: info@imq.it

**STATEMENT OF TEST RESULTS**

Additional Sheet to STR/2616/IMQ

**Description of the generic reference of the residual current operated circuit-breakers
with integral overcurrent protection for household and similar uses (RCBOs) series DPN Vigi**

P1B 6000**Colour of the case:**

blank = grey case

b = white case

Rated residual current:10 = 10 mA ⁽¹⁾

30 = 30 mA

300 = 300 mA

Type:

A = type A

Asi = type Asi ⁽²⁾

AC = type AC

Rated current:

4 = 4 A

6 = 6 A

10 = 10 A

13 = 13 A

16 = 16 A

20 = 20 A

25 = 25 A

32 = 32 A

40 = 40 A

Curve:

blank = curve B

C = curve C

Rated short-circuit capacity:

6000 = 6000 A

Basic reference of the series:**P1B**⁽¹⁾ – Available only for RCBOs:

- Curve B, rated current 16 A, type A
- Curve C, rated current 10 and 16 A, type A

⁽²⁾ – Available for RCBOs curve C only.

"Asi"-type RCBOs are A-type RCBOs having an intentional short-time delay.