

Attestation



Eurofins Product Testing A/S received 10 insulation samples, representing in a generic way for the wide range and varieties of typical FEF (Flexible Elastomeric Foam) products marketed in the EU from

CEFEP (European Group of FEF manufacturers)

Sampling, testing and evaluation were performed according to CEN TS 16516, AgBB, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 in the latest versions, see the test report no. 392-2013-GSH-CEFEP_01.

All results were clearly below the limit values. For example the determined TVOC after 28 days was for all samples below 100 µg/m³.

Germany

The tested product complies with the requirements of DIBt (October 2010) and AgBB (June 2012).

France

CMR-Substances

The tested product fulfills the requirements of the French regulation DEVP0908633A of 30 April 2009 and DEVP0910046A of 28 May 2009.

VOC-emission classification

The tested product is classified to emission class A+. This recommendation is based on the French regulations of March 23 2011 (décret DEVL1101903D) and of April 19 2011 (arrêté DEVL1104875A).

Belgium

The tested product complies with the requirements of the Royal Decree for establishing threshold levels for the emissions to the indoor environment from construction products for certain intended uses (draft December 2012).

23 January 2014

Thomas Neuhaus
Head of product emission test centre

Eurofins Product Testing A/S
Smedeskovvej 38
DK-8464 Galten / Denmark
Tel +45 70 22 42 76
Fax +45 70 22 42 75