



## **CERTIFICATE FI 30593**

Our Ref. 292350-1

**Product** 

PVC-sheathed wiring cable

Type

MMJ

Certificate Holder/ Manufacturer

La Triveneta Cavi S.p.A.

Via orna, 35

IT-36040 BRENDOLA (VI), ITALY

**Technical information** 

MMJ 2-5 x 1,5-2,5 mm<sup>2</sup> MMJ 2-5 x 6-25 mm<sup>2</sup>

Other information

MMJ 2-5 x 1,5-2,5 mm<sup>2</sup>, rated voltage 300/500 V

MMJ 2-5 x 6-25 mm<sup>2</sup>, rated voltage 450/750 V

The product is certified

according to the following standard(s) SFS 2091:2011

Validity

This certificate is valid until 09 October 2023 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any)

will be approved at SGS Fimko before the product is brought onto market.

Directive information

The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

Date of issue

09 October 2018

SGS Fimko Ltd

Signature

Sixten Lökfors **Project Manager** 

This certificate has 1 appendix

This certificate is issued by the company under its General Conditions for Certification Services accessible at <a href="http://www.sgs.fi/en/Terms-and-Conditions.aspx">http://www.sgs.fi/en/Terms-and-Conditions.aspx</a>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



Appendix to Certificate: 30593

Manufacturing sites

La Triveneta Cavi S.p.A. Via orna, 35 IT-36040 BRENDOLA (VI), ITALY

La Triveneta Cavi S.p.A. Via Alcide De Gasperi, 19 IT-36040 BRENDOLA (VI), ITALY

Additional information

FINAS
Finnish Accreditation Service
S003 (EN ISO/IEC 17065)

This certificate replaces Certificate FI 28249 A1 dated 15 November 2013, due to new testing and removed type MKMJ.